

# VOC Content Test Certificate

Tuesday, 2<sup>nd</sup> August 2011

Manufacturer: Ductware (6-10 Market Road, Sunshine VIC 3020)

Sample Description: Ductmate Water-based Everseal

Tested: September 2010

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<p align="center"><b>Specification</b></p> <p align="center"><b>Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11 New Zealand Green Building Council Green Star NZ Office 2009 IEQ-3 Green Star NZ Office Interiors IEQ-3</b></p>	<p align="center"><b>Ductmate Water-based Everseal</b></p>
<p>Architectural sealant 250 grams per Litre as VOC content material</p>	<p align="center"><b>31 grams per Litre as VOC content material</b></p>
<p align="center"><b>Green Building Council of Australia Green Star Office Design V3 IEQ-13 Green Star Education V1 IEQ-8</b></p>	<p align="center"><b>Ductmate Water-based Everseal</b></p>
<p>Architectural sealant 250 grams per Litre as VOC content material</p>	<p align="center"><b>31 grams per Litre as VOC content material</b></p>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

**F1009-18**