

VOC Content Test Certificate

Tuesday, August 02, 2011

Manufacturer: Ductmate Industries Inc (Charleroi, Pennsylvania USA)

Australian Distributor: Ductware, a Division of RMD Industries Pty Ltd (Melbourne, Sydney, Brisbane, Adelaide, Perth)

Sample Description: Proseal (high velocity duct sealant)

Date Tested: July 2009 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<p align="center">Specification</p> <p>Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11</p>	<p>Proseal</p>
<p>Architectural Sealant 250 grams per Litre as VOC content material</p>	<p><1 gram per Litre as VOC content material</p>
<p>Green Building Council of Australia Green Star Office Design V3 IEQ-13 Green Star Education V1 IEQ-8</p>	<p>Proseal</p>
<p>Architectural Sealant 250 grams per Litre as VOC content material</p>	<p><1 gram per Litre as VOC content material</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F0907-04